

## **Certificate of Compliance**

Certificate: 2536235 Master Contract: 256065

**Project:** 2536235 **Date Issued:** July 18, 2012

**Issued to:** Silevo Inc

**45645 Northport Loop East** 

Fremont, CA 94538

**USA** 

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Brý Aggarwal

Issued by: Brij Aggarwal, P.Eng.

## **PRODUCTS**

**CLASS 5311 10** - POWER SUPPLIES - Photovoltaic Modules and Panels

CLASS 5311 90 - POWER SUPPLIES - Photovoltaic Modules and Panels - Certified to US

Standards

Photovoltaic Modules with maximum system voltage of 600 V dc and Class C fire class rating, Model Series Triex U series and Triex U series Black, with power output from 290 W to 310 W and series Triex R series and Triex R series Black with power output from 215 W to 235 W, in 5W steps, with the following electrical ratings typical at 295 and 220 W respectively @ Standard Test Condition (STC):

Open Circuit Voltage (Voc): 69.5/52.2 V

Short Circuit Current (Isc): 5.56/5.56 A

Operating Voltage (Vpmax): 57.0/42.7 V

Current at Operating Voltage (Ipmax): 5.19/5.19 A

## Notes:

Rated electrical characteristics are within  $\pm$  3% of measured values at Standard Test Conditions of 100 mW/cm2 irradiance, AM 1.5 spectrum, and cell temperature of 25°C.

DQD 507 Rev. 2012-05-22 Page: 1



Certificate: 2536235 Master Contract: 256065

**Project:** 2536235 **Date Issued:** July 18, 2012

## **APPLICABLE REQUIREMENTS**

ULC/ORD- C1703-01 - Flat-Plate Photovoltaic Modules and Panels

UL 1703-3rd Edition - Flat-Plate Photovoltaic Modules and Panels

DQD 507 Rev. 2012-05-22 Page: 2